



Catherine E. Heigel, Director

Promoting and **BUREAU OF WATER** *and the environment*

January 28, 2016

To: Robert Doub Jr
Town of Edisto Beach (1510006)
2414 Murray St
Edisto Beach, SC 29438

From: Idris Liban
Drinking Water Compliance Monitoring Section
Water Enforcement Division

Re: Lead and Copper Sampling Results

Enclosed are the Lead and Copper test results for the June 1 – September 30, 2015 monitoring period. Your water system did not exceed the action levels for lead or copper at the 90th Percentile. The action levels for lead and copper are 0.015 mg/l and 1.3 mg/l, respectively. These results must be kept on file for at least twelve (12) years.

Your water system is scheduled to sample again June 1, 2018 – September 30, 2018. Please remember to use the same sampling sites and their corresponding tracking codes (T-Codes). If a site is not available, a Justification for Change of Sample Site form must be submitted along with the type of plumbing and year it was installed.

Please fill out the attached Customer Notification Certification page and send it back to the following address:

**S.C. Department of Health and Environmental Control
Bureau of Water
Drinking Water Compliance Monitoring Section
ATTN: Lead and Copper Program Manager
2600 Bull St.
Columbia, SC 29201**

If you have any questions, please contact me at (803) 898-3573 or E-mail libani@dhec.sc.gov.

Enclosure



Catherine E. Heigel, Director

Promoting and protecting the health of the public and the environment

Lead and Copper Sample Results

SC1510006 EDISTO BEACH TOWN OF (1510006)

Lab ID 32010

Lead 90th Percentile: 0.0 mg/L

Copper 90th Percentile: 0.077 mg/L

The 90th Percentiles are based on **20** samples.

Coll Date	T-Code	Sample Location	Analyte	Result	UOM
9/17/2015	T3A0040	119 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0040	119 PALMETTO BLVD	COPPER,	0.010	MG/L
9/17/2015	T3A0039	204 PALMETTO BLVD	COPPER,	0.061	MG/L
9/17/2015	T3A0039	204 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0038	208 PALMETTO BLVD	COPPER,	0.000	
9/17/2015	T3A0038	208 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0030	1522 DOROTHY ST	COPPER,	0.010	MG/L
9/17/2015	T3A0030	1522 DOROTHY ST	LEAD	0.000	
9/17/2015	T3A0022	3514 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0022	3514 PALMETTO BLVD	COPPER,	0.022	MG/L
9/17/2015	T3A0021	3332 PALMETTO BLVD	COPPER,	0.011	MG/L
9/17/2015	T3A0021	3332 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0020	3306 PALMETTO BLVD	COPPER,	0.000	
9/17/2015	T3A0020	3306 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0018	3301 PALMETTO BLVD	COPPER,	0.077	MG/L
9/17/2015	T3A0018	3301 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0017	3216 PALMETTO BLVD	COPPER,	0.026	MG/L
9/17/2015	T3A0017	3216 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0016	3125 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0016	3125 PALMETTO BLVD	COPPER,	0.000	
9/17/2015	T3A0015	3101 PALMETTO BLVD	LEAD	0.000	

Page 1 of 2

Coll Date	T-Code	Sample Location	Analyte	Result	UOM
9/17/2015	T3A0015	3101 PALMETTO BLVD	COPPER,	0.046	MG/L
9/17/2015	T3A0014	2901 PALMETTO BLVD	COPPER,	0.033	MG/L
9/17/2015	T3A0014	2901 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0013	2506 PALMETTO BLVD	COPPER,	0.130	MG/L
9/17/2015	T3A0013	2506 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0012	2103 POINT ST	COPPER,	0.011	MG/L
9/17/2015	T3A0012	2103 POINT ST	LEAD	0.000	
9/17/2015	T3A0011	2505 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0011	2505 PALMETTO BLVD	COPPER,	0.000	
9/17/2015	T3A0010	1901 PALMETTO BLVD	COPPER,	0.000	
9/17/2015	T3A0010	1901 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0009	1001 PALMETTO BLVD	COPPER,	0.027	MG/L
9/17/2015	T3A0009	1001 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0002	216 PALMETTO BLVD	COPPER,	0.000	
9/17/2015	T3A0002	216 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T3A0001	111 PALMETTO BLVD	COPPER,	0.120	MG/L
9/17/2015	T3A0001	111 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T1A0601	603 PALMETTO BLVD	LEAD	0.000	
9/17/2015	T1A0601	603 PALMETTO BLVD	COPPER,	0.017	MG/L

Public Notification Certification

Water System Name: TOWN of Edisto Beach

Water System I.D. 1510006

I confirm that the Public Notification has been distributed to our customers and appropriate notices of availability have been given. Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data provided by the primacy agency.

Certified by: Name: ROBERT W. DOUB, JR

Title: UTILITIES DIRECTOR

Phone # 843-869-2505 Date 1-29-16